



We help ideas meet the real world



Compliance Statement

No. 2009-180

Unscreened Channel, Class E

Company

Hyperline Systems Canada Ltd.
2212 Gladwin Crescent, Unit 7
Ottawa, Ontario K1B 5N1
Canada

Channel Identification (2 connector model)

Horizontal cable:

Hyperline Systems Canada Ltd. Cat. 6 UTP 23AWG

Wall Outlet:

Hyperline Systems Canada Ltd Cat. 6 UTP

Patch Panel:

Hyperline Systems Canada Ltd Cat. 6 UTP

Generic cabling standards, cabling components standard

- ISO/IEC 11801 amendment 1:2002
- EN 50173:2007
- ANSI/TIA/EIA-568-B.
- ANSI/TIA/EIA-568-B.2-1

Technical report

DELTA-N312632, DANAK-19J2115

Manufacturer code

1894B

Certificate valid until

27 August 2010

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 27 August 2009

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.delta.dk/cable



TEST Reg. no. 19